

**TITLE 380. OKLAHOMA DEPARTMENT OF LABOR  
CHAPTER 25. BOILER AND PRESSURE VESSEL RULES**

**SUBCHAPTER 3. ADMINISTRATION**

**380:25-3-7. Inspection reports to be submitted by inspectors (excludes owner/user agencies under the scope of API)**

- (a) Inspectors shall submit to the Chief Boiler Inspector an inspection report on form NB-5 for each non-standard boiler or pressure vessel.
- (b) Subsequent inspections of both standard and non-standard boilers and pressure vessels shall be reported on Forms NB-6 or NB-7 of the National Board Inspection Code.
- (c) Inspection reports as required in Section 380:25-3-7(a)&(b), shall be submitted within thirty days from date of inspection.
  - (1) If the insurance company special inspectors have made the required inspection but have not submitted the report to the Bureau of Boiler Inspection within thirty (30) days, the insurance company may be charged a fee equal to that contained in Section 141.16(A)(2)(f) for each month or part thereof they are late.
  - (2) If insurance company special inspectors do not file their inspection reports with the Bureau of Boiler Inspection within ninety (90) days from the date the inspection is due, the Bureau of Boiler Inspection may make the required inspection and charge the insurance company an inspection fee equal to that contained in Section 141.16(A)(2)(g).
- (d) In lieu of forms NB-5, -6, or -7, referred to in this section, reasonable facsimiles approved in advance by the Chief Boiler Inspector may be used.
- (e) In addition, vessel heating surface or BTU (British Thermal Units) input or other data which will determine the maximum output of the unit and the relieving capacity of all safety, relief, or safety relief valves will be shown on all reports.
- (f) All reports of inspection of hot water supply heaters covered by the Act shall be submitted on forms approved by the Commissioner.