



# Amendment of Solicitation

Date of Issuance: April 4, 2018

Solicitation No. REBID 1310004216

Requisition No. 1310019324

Amendment No. 2

Hour and date specified for receipt of offers is changed:  No  Yes, to: \_\_\_\_\_ CST

Pursuant to OAC 260:115-7-30(d), this document shall serve as official notice of amendment to the solicitation identified above. Such notice is being provided to all suppliers to which the original solicitation was sent. Suppliers submitting bids or quotations shall acknowledge receipt of this solicitation amendment prior to the hour and date specified in the solicitation as follows:

- (1) Sign and return a copy of this amendment with the solicitation response being submitted; or,
- (2) If the supplier has already submitted a response, this acknowledgement must be signed and returned prior to the solicitation deadline. All amendment acknowledgements submitted separately shall have the solicitation number and bid opening date printed clearly on the front of the envelope.

**ISSUED BY and RETURN TO:**

**U.S. Postal Delivery:**

5005 N. Lincoln, Blvd Ste. 300  
Oklahoma City, OK 73105

or

**Personal or Common Carrier Delivery:**

5005 N. Lincoln Blvd Ste. 300 Oklahoma City, OK  
73105

Shanica Burdex  
Contracting Officer

405- 522 - 8404  
Phone Number

Shanica.Burdex@omes.ok.gov  
E-Mail Address

**Description of Amendment:**

a. This is to incorporate the following:

**Please see below for information regarding this solicitation**

This amendment is to correct the Hz for the generator listed under the Minimum Specifications on the REBID – Attachment A Solicitation Request. The corrected Solicitation Request is attached.

A strikethrough denotes a deletion and an underline denotes an addition.

Minimum Specifications:

Standby Power Rating- 60 kW, 60 kVA, ~~50 Hz~~ 60Hz

**Question to Bidders**

- Per the bid that you submitted, is your bid based on the specifications listed within Section C. of the solicitation or is your bid based on the Minimum Specifications listed on REBID - Attachment A Solicitation Request?
- If your bid was based on Section C. of the solicitation, you do not need to resubmit a new bid. However, if your bid was based on the Minimum Specifications listed on the REBID – Attachment A Solicitation Request, please submit your new Best and Final Offer bid response by the due date below.

Please submit your response to this amendment by Friday April 6, 2018 by 5:00 pm Central Time.

---

b. All other terms and conditions remain unchanged.

---

Supplier Company Name (**PRINT**)

---

Date

---

Authorized Representative Name (**PRINT**)      Title

---

Authorized Representative Signature



# SOLICITATION REQUEST

 Request for Quote

 Request for Proposal

 Request for Bid

**Dispatch via Print**

**Department of Corrections**  
 DEPARTMENT OF CORRECTIONS  
 3400 MARTIN LUTHER KING AVE  
 OKLAHOMA CITY OK 73111-4298

Request Quote ID.	Date	Buyer	Page
1310004216	01/18/2018	Shanica Burdex	1
Payment Terms	DateTime Quote Open	Closing	
0 Days	02/28/2018 02:30 PM	03/20/2018 03:00 PM	

Requisition Number Reference: From Req ID - 1310019324

**Ship To:** DEPARTMENT OF CORRECTIONS  
 LEXINGTON A & R CENTER  
 15151 E HWY 39  
 LEXINGTON OK 73051

**Bill To:** DEPARTMENT OF CORRECTIONS  
 BUSINESS SERVICES  
 PO BOX 11400  
 OKLAHOMA CITY OK 731360400

**Supplier:** NAME \_\_\_\_\_  
 Address: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 City: \_\_\_\_\_ ST: \_\_\_\_\_ ZIP: \_\_\_\_\_

**Supplier Responses**

Line	Cat CD / Item # - Descr	Qty.	UOM	Unit Cost	Ext. Cost
1	26111601 / Diesel Generator	3	EA		

Brand: Generac SD060 or an approved equal.

Minimum Specifications:  
 Standby Power Rating- 60 kW, 60 kVA, 60 Hz  
 Electrical: 277/480 VAC Three Phase  
 Shall meet all applicable ETL, NFPA, NEC, ISO, NEMA, ANSI, ASCE, ICC-ES, IBC and CBC codes and standards.  
 2 Year Limited Warranty

**Freight Terms:** FOB DEST      **Ship Via:** COMMON

Lead Time: \_\_\_\_\_

**Supplier Remarks:**

2	26131803 / Transfer Switch For Above Unit	3	EA		
---	---	---	----	--	--

Shall be compatible with above unit.

Brand: Generac GTS100 or an approved equal.

Minimum Specifications:  
 100 amp  
 277/480 3 Phase  
 NEMA-3R Enclosure

**Freight Terms:** FOB DEST      **Ship Via:** COMMON

Lead Time: \_\_\_\_\_

**Supplier Remarks:**

**COMMENTS:**  
 One-Time Purchase. Shall include onsite start-up inspection.

Correctional Centers Only:  
 Notice to Suppliers  
 Security. Contractors employees, agents, and representatives shall comply with all security and identification procedures at DOC facilities. DOC is responsible for alerting Contractor to these requirements prior to the commencement of work.  
 Security requirements may include, but are not limited to:  
 Identification: All employees, agents, and representatives of the Contractor, while working on State property, shall carry or display acceptable identification.  
 Vehicle Security: Drivers must turn off vehicle motors and lock cab doors whenever their truck is unattended. Trucks shall be searched prior to entry and exit, causing up to a 30 minute delay each way.  
 Offender Contact: Contractors employees, agents, and representatives shall minimize interaction with offenders or patients, and shall report any verbal contact to DOC facility security staff before leaving

**This is NOT AN ORDER**

All returned quotes and related documents must be identified with our request for quote Number.

**Authorized Signature**



# SOLICITATION REQUEST

 Request for Quote Request for Proposal Request for Bid**Dispatch via Print**

**Department of Corrections**  
DEPARTMENT OF CORRECTIONS  
3400 MARTIN LUTHER KING AVE  
OKLAHOMA CITY OK 73111-4298

<b>Request Quote ID.</b>	<b>Date</b>	<b>Buyer</b>	<b>Page</b>
1310004216	01/18/2018	Shanica Burdex	2
<b>Payment Terms</b>	<b>DateTime Quote Open</b>	<b>Closing</b>	
0 Days	02/28/2018 02:30 PM	03/20/2018 03:00 PM	

Requisition Number Reference: From Req ID - 1310019324

**Ship To:** DEPARTMENT OF CORRECTIONS  
LEXINGTON A & R CENTER  
15151 E HWY 39  
LEXINGTON OK 73051

**Bill To:** DEPARTMENT OF CORRECTIONS  
BUSINESS SERVICES  
PO BOX 11400  
OKLAHOMA CITY OK 731360400

**Supplier:** NAME

Address: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ ST: \_\_\_\_\_ ZIP: \_\_\_\_\_

**Supplier Responses**

Line	Cat CD / Item # - Descr	Qty.	UOM	Unit Cost	Ext. Cost
------	-------------------------	------	-----	-----------	-----------

the site.

Subject to Search: All persons, vehicles, packages and equipment entering a DOC facility are subject to search. Persons are typically pat searched and required to clear metal detection devices. Packages, briefcases, purses, etc., searched with x-ray equipment. Drug K-9 may also be used to search persons, vehicles, packages, and equipment.

Contraband: Contractors employees, agents, and representatives shall not have any weapons (including jack knives or box cutters), cell phones, pagers, drugs, tobacco products or any item deemed by facility to be potential contraband. Correctional officers can hold these items for delivery drivers at the delivery sally-port and return them as the driver exits the grounds. Any illegal items shall not be returned and shall be reported to local law enforcement.

Security Clearance: Contractors employees, agents, and representatives who enter secure facilities shall have prior approval to enter from facility security staff, generally involving a background check to ensure that they are not convicted felons. The Contractor shall submit background check requests a minimum of two weeks prior to arriving at the facility. At the facilities discretion, Contractor shall comply with any requests to reassign a Contractor employee, agent, or representative, whether or not the individual has passed the background check if it is determined by facility that there is a security concern.

Tobacco Use Prohibited. The use of tobacco products is prohibited throughout all indoor and outdoor areas of property owned, leased, loaned or under the control of DOC, including parking lots owned or under the control of DOC.

**This is NOT AN ORDER**

All returned quotes and related documents must be identified with our request for quote Number.

**Authorized Signature**