

Safety-Gram

Title 45, Chapter 11



TAKE IT TO HEART

SECTION 910 – PROPER GROUND CONTROL

SECTION 910.B3		Areas surrounding flammable-liquid storage tanks and electric substations and transformers shall be kept free from dry grass, weeds, underbrush and other combustible materials for at least twenty-five(25)feet in all directions.
SECTION 910.B5		Buildings or rooms in which oil, grease, flammable liquids or similar flammable materials are stored shall be of fire-resistant construction and well ventilated. Provisions shall be made to control spilled flammable liquids.
SECTION 910.B7		Combustible materials, grease, lubricants or flammable liquids shall not be allowed to accumulate where they can create a fire hazard.
SECTION 910.B16		Fire-fighting equipment shall be strategically located, readily accessible, plainly marked, properly maintained and inspected periodically with records kept of such inspections.
SECTION 910.B17.a	Fire Extinguishers shall be: Adequate in number and size and of the appropriate type for each particular fire hazard involved.	

SPREAD THE LOVE OF SAFETY!

