

Oklahoma Uniform Code Plumbing/Fuel Gas Technical Review Committee

Minutes

Monday, October 4, 2010

CIB Offices

2401 NW 23rd Street, Suite #5

Oklahoma City, Oklahoma

- A. Call to order 2:30 p.m.
- B. Roll Call Members Present – Ronnie Smith, Chris Brierly, Carl Boone, Tony Blatt, Randy Carter, George Hillman, Denis Mantooth, Greg Armstrong, John Taylor, Larry Kellner, Jerry Cerroll
- C. Approvals of minutes from last committee meeting
- D. Announcements
- E. Review of 2009 IRC codes

P2503.6 Shower liner test. Where shower floors and receptors are made water tight by the application or materials required by Section P2709.2, completed liner installation shall be tested ~~insert – at plumbing final.~~

P2503.8 Inspection and testing of backflow prevention devices.

Leave as written

P2603.5 Pipes through footings or foundation walls.

Leave as written

P2709.2.1 Lining Required.

~~insert – Where required –~~ the adjoining walls and floors framing enclosing on-site built-up receptors shall be lined with one of the following: ----

Section P2715

Laundry ~~(delete Tubs)~~ ~~insert – Tray~~

P2715.1 Laundry ~~(delete Tubs)~~ ~~insert – Tray waste outlets.~~ Each compartment of a laundry ~~(delete tub)~~ ~~tray~~ shall be provided with a waste outlet not less than 1 1/2 inches-----

P2801.5 Required pan. Where ~~insert – tank type~~ water heaters or hot water storage tanks-----

4:00 Kellner absent

P2803.1 Relief valves required. ~~insert – Tank type~~ appliance and equipment used for heating water or storing hot water shall be protected by:-----

P2902.5.3 Lawn irrigation systems. The potable water supply to lawn irrigation systems shall be protected against backflow by an atmospheric-type vacuum breaker, a pressure-type vacuum breaker, ~~(delete) or~~ a reduced pressure principal backflow preventer ~~insert – or a spill resistant backflow preventer.~~-----

P2903.1 Service valve. Each swelling unit shall be provided with an accessible main shutoff valve near the entrance of the water service. The valve shall be of a full-open type having nominal restriction to flow ~~insert – (delete) with a provision for drainage such as a bleed orifice or installation of a separate drain valve.~~-----

P2903.8.6 Hose bibb bleed. ---insert--- Where authority having jurisdiction a readily accessible air bleed shall be installed in hose bibb supplies-----

P2903.10 Hose bibb. Hose bibs subject to freezing, including the “frost-proof” type, shall be equipped with an accessible (delete) stop and waste type valve inside the building so that they-----
(delete) entire Exception.

- F. Review and discuss any written proposed codes changes
Only one received at this time
- G. Assign review task to committee members
None assigned
- H. Adjournment 5:30 p.m.