



OKLAHOMA UNIFORM BUILDING CODE COMMISSION RULES

748 - Uniform Building Code Commission Adopted Codes

International Fire Code®, 2015 Edition (IFC®, 2015) 748:20-3-1 through 748:20-3-15

NOTICES:

1. Section headers within this document marked "Revoked" do not revoke the current chapter associated with this revocation language. This language simply means the modifications made in a previous adoption have been "revoked" and the language reverts to the published content of the currently adopted code without amendment.
2. Through its rulemaking process, the OUBCC has adopted the first printing of the 2015 edition of the International Fire Code® (IFC®, 2015), which has been promulgated as a permanent rule pursuant to Oklahoma law at OAC 748:20-3-1. Errata found and corrected by the ICC®, if any, in a printing of the code other than the specific printing listed previously in this notice, has not been reviewed or approved by any OUBCC technical committee, adopted by the OUBCC itself, or promulgated as a permanent rule by the OUBCC pursuant to Oklahoma law.
3. The rules of the Oklahoma Uniform Building Code found on this website are **unofficial**. The official rules are published in The Oklahoma Administrative Code and The Oklahoma Register, as required by 75 O.S. § 250 et seq. To order an official copy of these rules, contact the Office of Administrative Rules at: (405) 521-4911.

CHAPTER 20 - ADOPTED CODES

[Authority: 59 O.S. 59 § 1000.23]
[Source: Codified 7-15-11]

SUBCHAPTER 3 - IFC® 2015

[Source: Reserved at 28 Ok Reg 2122, eff 7-15-11, Amended at 29 Ok Reg 1646, eff 11-1-12; Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-1. Adoption of International Fire Code®, 2015 Edition (IFC® 2015)

(a) The Oklahoma Uniform Building Code Commission (the "OUBCC") hereby adopts the International Fire Code®, 2015 Edition (IFC® 2015) as amended and modified in this subchapter as the statewide minimum code for residential and commercial fire prevention and fire protection systems in the State of Oklahoma pursuant to 59 O.S. § 1000.23.

(b) The OUBCC through formal action expressly chose to adopt the IFC® 2015 as amended and modified in this subchapter, as the statewide minimum code for residential and commercial fire prevention and fire protection systems in the State of Oklahoma. In like manner, the OUBCC through formal action expressly chose to not adopt the International Fire Code®, 2012 Edition (IFC®, 2012) for any purpose.

(c) As part of its 2012 code cycle, the International Code Council, Inc. (ICC) reorganized the format of certain of its model codes as it was foreseeable to ICC that additional chapters will need to be added in the future as model regulations for new processes or operations are developed. The format reorganization was designed by ICC to accommodate such future chapters by providing reserved (unused) chapters in several parts of certain of its model codes as part of its 2012 code cycle. The format reorganization continues into the ICC's 2015 code cycle and is adopted by the OUBCC to the extent provided in this subchapter by the phrase "reserved for future use" inserted in lieu of titles for chapters.

(d) This material contains information which is proprietary to and copyrighted by the International Code Council, Inc. The acronym "ICC" and the ICC logo are trademarks and service marks of ICC. ALL RIGHTS RESERVED.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15, Amended at 34 OK Reg 2107, eff 9-15-17]

748:20-3-2. Effect of Adoption

The IFC® 2015 as amended and revised by these rules is hereby established and adopted as the statewide minimum code for residential and commercial fire prevention and fire protection systems in the State of Oklahoma pursuant to 59 O.S. 1000.23, and may only be amended or altered by other jurisdictions pursuant to Oklahoma law and the administrative rules of the OUBCC as set forth in Title 748, Chapter 15 of the Oklahoma Administrative Code.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-3. IFC® 2015 and Other Appendices

(a) None of the appendices of the IFC® 2015 have been adopted by the OUBCC for inclusion in the statewide minimum code for residential and commercial fire prevention and fire protection systems in the State of Oklahoma.

(b) The OUBCC hereby creates a new appendix entitled "Appendix N, Egress Path Markings for Existing Buildings."

(c) The OUBCC has removed from Chapter 11 of the IFC® 2015 Section 1104.25 entitled "Egress Path Markings" and has relocated and renumbered the section to the newly created Appendix N entitled "Egress Path Markings for Existing Buildings."

(d) Appendices A through N are not adopted as the statewide minimum code for residential and commercial fire prevention and fire protection systems within the State of Oklahoma. However, other jurisdictions within the State of Oklahoma may adopt any or all of said appendices in accordance with 59 O.S. § 1000.29.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-4. IFC® 2015 Provisions Adopted and Modified

(a) All chapters and provisions within chapters, including exceptions, of the IFC® 2015 not specifically addressed within these rules as being modified, deleted, moved or removed are hereby adopted without

modification as the statewide minimum code for residential and commercial fire prevention and fire protection systems within the State of Oklahoma pursuant to 59 O.S. § 1000.23. Chapters and provisions within chapters, including exceptions adopted with modifications are specifically addressed in these rules.

(b) The ICC® has reserved Chapters 12 through 18, Chapters 38 through 49, Chapter 52, and Chapters 68 through 79 for possible future use. The OUBCC has not adopted Chapters 12 through 18, Chapters 38 through 49, Chapter 52, and Chapters 68 through 79 and these chapters are not considered part of the statewide minimum code for residential and commercial fire prevention and fire protection systems within the State of Oklahoma.

(c) To the extent any references in the IFC® 2015 as amended and modified in this sub-chapter are made to any other code or standard, the particular edition for that reference is defined in the referenced standards found in the IFC® 2015 as amended and modified in this sub-chapter and in the IFC® 2015 Chapter 80 entitled "Referenced Standards."

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-5. Participation in Federal Programs and/or Federally Funded or Financed Projects

In order to maximize federal financial aid, assistance, participation, financing and/or funding in any public project(s) and/or federal financial aid, participation, funding for and participation in any federal program(s) by the State of Oklahoma, its agencies, public trusts and instrumentalities, or by any Oklahoma municipalities and other political subdivisions, that receive financial aid, assistance, participation, financing and/or funding for and participate in any federal program(s), the State of Oklahoma, its agencies and instrumentalities, and any Oklahoma municipalities and other political subdivisions, may cooperate with the United States Government and any agency or instrumentality thereof, in the manner authorized and provided by federal law and regulation and in doing so may perform all necessary functions and take all necessary actions for accomplishing such federal purposes and programs, including but not limited to, following and/or complying with federal laws, regulations and/or requirements arising from or related to federal financial aid, assistance, participation, financing and/or funding, in the construction, alteration, movement, enlargement, replacement, repair, equipment, use and occupancy, location, improvement, expansion, operation, maintenance, removal, and demolition of buildings and structures or any appurtenances attached to such buildings or structures, notwithstanding any provisions of any and all uniform building codes and standards adopted by the OUBCC to the contrary.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-6. IFC® 2015 Chapter 1 Scope and Administration

Chapter 1 of the Oklahoma adopted IFC® 2015, includes the following Preamble at the very beginning of the chapter:

(1) Pursuant to 59 O.S. § 1000.23, the OUBCC has adopted the IFC® 2015 as amended and revised by the Commission, as the statewide minimum code to be used by all entities for residential and commercial fire prevention and fire protection systems in jurisdictions throughout the State of Oklahoma. However, the OUBCC's adoption of Chapter 1 "Scope and Administration" of the IFC® 2015 is for continuity purposes and the OUBCC's adoption of Chapter 1 recognizes the methods of best practice in fully implementing the statewide minimum code for residential and commercial fire prevention and fire protection systems.

(2) All provisions of the adopted IFC® 2015, including Chapter 1, as amended and revised by the OUBCC, are hereby established and adopted as the statewide minimum code for residential and commercial fire prevention and fire protection systems in Oklahoma pursuant to 59 O.S. § 1000.23, which may only be amended or altered pursuant to Oklahoma law and the administrative rules of the OUBCC as set forth in Title 748, Chapter 15 of the Oklahoma Administrative Code. However, the provisions of Chapter 1 adopted herein are only intended to be in force and effect to the extent that the respective provisions do not conflict with State law or the lawful exercise of code administration and enforcement jurisdiction by entities empowered to do so pursuant to applicable law.

(3) Section 105.1.1 Annual permit. This section has been modified to clarify what an annual permit is. This section shall read: An annual permit is a yearly permit which represents a group of individual permits for each alteration to an already approved electrical, gas, mechanical or plumbing installation. The building official is authorized to issue an annual permit upon application therefor to any person, firm or

corporation regularly employing one or more qualified tradespersons in the building, structure or on the premises owned or operated by the applicant for the permit.

(4) Section 105.1.2 Annual permit records. This section has been modified to require the building official to collect the OUBCC permit fee for each individual permit that is part of the annual permit at the completion of the annual permit term. This section has been modified to read: Annual permit records. The person to whom an annual permit is issued shall keep a detailed record of alterations made under such annual permit. The building official shall have access to such detailed records of alterations at all times. At the completion of the entity's annual permit term, the applicant shall file such detailed records of alterations with the building official. Pursuant to the authority of 59 O.S. § 1000.25, the building official shall collect fees for each individual permit which is part of the annual permit once the detailed records are submitted and remit such fees to the OUBCC.

(5) The OUBCC's adoption of Chapter 1 in this manner is made with the recognition that the legal authority granting state and local code administration and enforcement jurisdictions the power and discretion to administer and enforce codes arises from Oklahoma laws governing those jurisdictions. Furthermore, the OUBCC also recognizes that many state and local code administration and enforcement jurisdictions have already created, or have the lawful authority to create, departments, offices and administrative policies pursuant to various applicable laws and other adopted model codes with "Scope and Administration" provisions similar to Chapter 1 of the adopted IFC® 2015.

(6) This limited adoption of Chapter 1 is made in recognition of the authority and discretion possessed by jurisdictions to administer and enforce building codes. Exercising such authority and jurisdiction in a manner inconsistent with Chapter 1 must be supported by Oklahoma law. Code administration and enforcement jurisdictions shall not use the OUBCC's limited adoption of Chapter 1 to circumvent the remainder of the requirements established by the Oklahoma adopted IFC® 2015 and the OUBCC will strongly oppose any such practice.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-7. IFC® 2015 Chapter 2 Definitions

Chapter 2 of the IFC® 2015 is adopted with the following modifications:

(1) The definition of an AUTHORITY HAVING JURISIDCTION has been added to clarify the different individuals that may have authority with in the code. This definition has been added to read: AUTHORITY HAVING JURISDICTION. Means an organization, office, or individual responsible for enforcing the requirements of the State Adopted Building Codes, including the prior authorization or approval of any equipment, materials, installations or procedures used in all or part of the construction of a new, or alteration or renovation of an existing building or structure, including integral finishes, fixtures and building system therein.

(2) The definition of a DISPENSING AREA has been added to clarify multiple references in the code with regard to fuel dispensing. This definition has been added to read: DISPENSING AREA. The appropriate hazardous (classified) locations for the fuel being dispensed in accordance with the National Electrical Code® – NFPA® 70.

(3) The definition of a MAIN RAILROAD TRACK has been added to provide clarity to building code officials. This definition has been added to read: MAIN RAILROAD TRACK. That part of the railway, exclusive of switch tracks, branches, yards, and terminals upon which trains are operated by timetable or train order or both.

(4) The definition for Residential Group R-3 has been modified to clarify the International Residential Code® 2015 (IRC® 2015) can be utilized so long as the facilities have four or fewer rooms. This definition has been modified to read: [BG] Residential Group R-3. Residential R-3 occupancies where occupants are primarily permanent in nature and not classified as Group R-1, R-2, R-5, or I including Boarding houses (non-transient) with 16 or fewer occupants, Boarding houses (transient) with 10 or fewer occupants, Buildings that do not contain more than two dwelling units, Care facilities that provide accommodations for five or fewer persons receiving care, Congregate living facilities (non-transient with 16 or fewer occupants), Congregate living facilities (transient) with 10 or fewer occupants and Lodging houses with four or fewer guest rooms.

(A) [BG] Care facilities within a dwelling. Care facilities for five or fewer persons receiving care that are within a single-family dwelling are permitted to comply with the IRC® provided an automatic sprinkler system is installed in accordance with Section 903.3.1.3 or Section P2904 of the IRC®.

(B) [BG] Lodging houses. Owner-occupied lodging houses with four or fewer guest rooms shall be permitted to be constructed in accordance with the IRC®.

(5) The definition of a SELF-SERVICE STORAGE FACILITY from the International Building Code®, 2015 Edition (Section 202) has been added to the International Fire Code®, 2015 Edition. This definition has been added to read: SELF-SERVICE STORAGE FACILITY. Real property designed and used for the purpose of renting or leasing individual storage spaces to customers for the purpose of storing and removing personal property on a self-service basis.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15, Amended at 34 OK Reg 2107, eff 9-15-17]

748:20-3-7.1. IFC® 2015 Chapter 3 General Requirements

Chapter 3 of the IFC® 2015 is adopted with the following modification: Section 308.1.6.3 Sky lanterns. This section has been modified to prohibit the use of any sky lanterns in the State of Oklahoma. This section has been modified to read: 308.1.6.3 Sky lanterns. A person shall not release or cause to be released a sky lantern in the State of Oklahoma per Title 68 O.S. § 1624.1.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-8. IFC® 2015 Chapter 5 Fire Service Features

Chapter 5 of the IFC® 2015 is adopted with the following modification: Section 508.1.3 Size has been modified to include an exception to make the fire command center smaller when approved by the fire code official. This section has been modified to read: 508.1.3 Size. The fire command center shall be a minimum of 200 square feet (19 square meters) in area with a minimum dimension of 10 feet (3048 mm). Exception: When approved by the fire code official the fire command center can be reduced in size to not less than a minimum of 96 square feet (9 square meters) with a minimum dimension of 8 feet (2438 mm).

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-9. IFC® 2009 Chapter 6 Building Services and Systems [REVOKED]

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Revoked at 32 Ok Reg 2285, eff 11-1-15]

748:20-3-10. IFC® 2009 Chapter 8 Interior Finish, Decorative Materials and Furnishings [REVOKED]

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-11. IFC® 2015 Chapter 9 Fire Protection Systems

Chapter 9 of the IFC® 2015 is adopted with the following modifications:

(1) Section 903.2.7 Group M. This section has been modified to reword subsection 4 to provide a reasonable limit for these occupancies and adequate protection without excessive burden on Group M occupancies with small areas of upholstered furniture and mattresses. This section has been modified to read: 903.2.7 Group M. An automatic sprinkler system shall be provided throughout buildings containing a Group M occupancy where one of the following conditions exists:

(A) A Group M fire area exceeds 12,000 square feet (1115 square meters).

(B) A Group M fire area is located more than three stories above grade plane.

(C) The combined area of all Group M fire areas on all floors, including any mezzanines, exceeds 24,000 square feet (2230 square meters).

(D) A group M occupancy where the cumulative area used for the display and sale of upholstered furniture or mattresses exceeds 5,000 square feet (464 square meters).

(2) 903.2.9 Group S-1. This section has been modified to add an exception to the fifth requirement in the list for when an automatic fire sprinkler system is required. This section has been modified to read: 903.2.9 Group S-1. An automatic sprinkler system shall be provided throughout all buildings containing a Group S-1 occupancy where one of the following conditions exists:

(A) A Group S-1 fire area exceeds 12,000 square feet (1115 square meters).

(B) A Group S-1 fire area is located more than three stories above grade plane.

(C) The combined area of all Group S-1 fire areas on all floors, including any mezzanines, exceeds 24,000 square feet (2230 square meters).

(D) A Group S-1 fire area used for the storage of commercial motor vehicles where the fire area exceeds 5,000 square feet (464 square meters).

(E) A Group S-1 occupancy used for the storage of upholstered furniture or mattresses exceeds 2,500 square feet (232 square meters). Exception: Self-service storage facility where the fire area is less than 5,000 square feet (464 square meters).

(3) Section 907.2.3 Group E. This section has been modified to remove the requirement for an emergency voice/alarm system and require a fire alarm system in Group E occupancies. The section has been modified to read: 907.2.3 Group E. A manual fire alarm system that activates the occupant notification signal in accordance with Section 907.5 and installed in accordance with 907.6 shall be installed in Group E occupancies. When automatic sprinkler systems or smoke detectors are installed such systems or detectors shall be connected to the building fire alarm system. Exceptions:

(A) A manual fire alarm system is not required in Group E occupancies with an occupant load of 50 or less.

(B) Manual fire alarm boxes are not required in Group E occupancies where all of the following apply:

(i) Interior corridors are protected by smoke detectors

(ii) Auditoriums, cafeterias, gymnasiums or similar areas are protected by heat detectors or other approved detection devices.

(iii) Shop and laboratories involving dusts or vapors are protected by heat detectors or other approved detection devices.

(iv) The capability to activate the evacuation signal from a central point is provided.

(v) In buildings where normally occupied spaces are provided with a two-way communication system between such spaces and constantly attended receiving station from where a general evacuation alarm can be sounded, except in locations specifically designated by the fire code official.

(C) Manual fire alarm boxes shall not be required in Group E occupancies where all the following apply:

(i) The building is equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1.

(ii) The fire alarm system will activate on sprinkler waterflow.

(iii) Manual activation is provided from a normally occupied location.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-12. IFC® 2015 Chapter 10 Means of Egress

Chapter 10 of the IFC® 2015 is adopted with the following modifications:

(1) Section 1010.1.10 Panic and fire exit hardware. This section has been modified to add an exception to the requirement for panic hardware or fire exit hardware on the access doors for electrical rooms and working spaces. This section has been modified to read: 1010.1.10 Panic and fire exit hardware. Doors serving a Group H occupancy and doors serving rooms or spaces with an occupant load of 50 or more in a group A or E occupancy shall not be provided with a latch or lock other than panic hardware or fire exit hardware. Exceptions:

(A) A main exit of a Group A occupancy shall be permitted to have locking hardware in accordance with Section 1010.1.9.3, Item 2.

(B) Doors serving a Group A or E occupancy shall be permitted to be electromagnetically locked in accordance with Section 1010.1.9.9.

(2) Electrical rooms and working spaces with equipment operating at more than 600 volts, nominal, and equipment operating at 600 volts or less, nominal and rated 800 amperes or more and that contain overcurrent devices, switching devices or control devices with exit or exit access doors, shall be equipped with panic hardware or fire exit hardware. The doors shall swing in the direction of egress travel. Exception: Personnel entrance to and egress from doors of the electrical equipment working spaces that

are greater than 25 feet (7.6 m) from the nearest edge of the electrical equipment.

(3) Section 1015.6 Mechanical equipment, systems and devices. This section has been modified to clarify the circumstances under which guards shall be provided and to modify the exception to require the authority having jurisdiction approve the use of a fall/restraint system instead of guards. This section has been modified to read: 1015.6 Mechanical equipment, systems and devices. Guards shall be provided where various components that require services are located on a roof or elevated structure and have a condition as set forth in Sections 1015.6.1 through 1015.6.3. The guard shall be constructed so as to prevent the passage of a sphere 21 inches (533 mm) in diameter. Exception: When approved by the authority having jurisdiction, guards are not required where permanent fall arrest/restraint anchorage connector devices that comply with ANSI/ASSE Z 359.1 are affixed for use during the entire roof covering lifetime. The devices shall be reevaluated for possible replacement when the entire roof covering is replaced. The devices shall be placed not more than 10 feet (3048 mm) on center along hip and ridge lines and placed not less than 10 feet (3048 mm) from roof edges and the open sides of walking surfaces.

(4) Section 1015.6.1 Roof edge. This section has been added to clarify the circumstances required to exist for the installation of guards at the roof edge when the components needing service are within a specific distance of the roof edge. This section has been added to read: 1015.6.1 Roof edge. Guards shall be provided when components are located within 10 feet (3048 mm) of a roof edge or open side of a walking surface or elevated structure and such edge or open side is located more than 30 inches (762 mm) above the floor, roof, or grade below. The guard shall extend not less than 30 inches (762 mm) beyond each end of the component that requires service.

(5) Section 1015.6.2 Skylights. This section has been added to clarify the circumstances for the installation of guards around components near skylights and to provide exceptions to the requirement. This section has been added to read: 1015.6.2 Skylights. Guards shall be provided when a skylight is within 10 feet (3048 mm) of the component that requires service. The guard shall extend 30 inches (762 mm) beyond the edge of the skylight. Exceptions:

(A) Guards are not required when the skylight is located at least 42 inches (1067 mm) above the highest point of the walking surface adjacent to the skylight or component.

(B) Guards are not required if some other provision for skylight fall-thru protection is provided and approved by the authority having jurisdiction.

(6) Section 1015.6.3 Roof hatch. This section has been added to clarify the circumstances for the installation of guards around components installed within a specific distance from the roof hatch. This section has been added to read: 1015.6.3 Roof hatch. Guards shall be provided when a roof hatch is within 10 feet (3048 mm) of the component that requires service. The guard shall extend 30 inches (762 mm) beyond the edge of the roof hatch. If the component is within 10 feet (3048 mm) of the ladder access side of the roof hatch, the guard shall incorporate a self-closing, self-latching gate. The gate shall have a top edge of not less than 42 inches (1067 mm) above the elevated surface adjacent to the gate and shall not allow the passage of a 21 inch (533 mm) sphere.

(7) Section 1015.7 Roof access. This section has been modified to require the authority having jurisdiction approve the use of a fall-restraint system instead of a guard in the exception. This section has been modified to read: 1015.7 Roof access. Guards shall be provided where the roof hatch opening is located within 10 feet (3048 mm) of a roof edge or open side of a walking surface and such edge or open side is located more than 30 inches (762 mm) above the floor, roof or grade below. The guard shall be constructed so as to prevent the passage of a sphere 21 inches (533 mm) in diameter. Exception: When approved by the authority having jurisdiction, guards are not required where permanent fall arrest/restraint anchorage connector devices that comply with ANSI/ASSE Z 359.1 are affixed for use during the entire roof covering lifetime. The devices shall be reevaluated for possible replacement when the entire roof covering is replaced. The devices shall be placed not more than 10 feet (3048 mm) on center along hip and ridge lines and placed not less than 10 feet (3048 mm) from roof edges and the open sides of the walking surfaces.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-13. IFC® 2015 Chapter 11 Construction Requirements for Existing Buildings

Chapter 11 of the IFC® 2015 is adopted with the following modifications:

(1) Section 1101.1 Scope. This section has been modified to include an exception allowing for structures complying with the International Existing Building Code® (IEBC®) be considered safe enough to where the provisions of Chapter 11 would not apply and resolve discrepancies between the two codes. This section has been modified to read: 1101.1 Scope. The provisions of this chapter shall apply to existing buildings constructed prior to the adoption of this code. Exception: Buildings or portions of a building that comply with the latest edition of the IEBC® or the edition that was adopted at the time a remodel occurred.

(2) Section 1103.4.2 Three to five stories. This section has been modified to add a fifth exception to provide relief from this section of the code when vertical openings comply with the requirements of Section 803.2.1 of the IEBC®. This section has been modified to read: 1103.4.2 Three to five stories. In other than Group I-2 and I-3 occupancies, interior vertical openings connecting three to five stories shall be protected by either 1-hour fire-resistant-rated construction or an automatic sprinkler system shall be installed throughout the building in accordance with Section 903.3.1.1 or 903.3.1.2. Exceptions:

(A) Vertical opening protection is not required for Group R-3 occupancies.

(B) Vertical opening protection is not required for open parking garages.

(C) Vertical opening protection for escalators shall be in accordance with Section 1103.4.5, 1103.4.6 or 1103.4.7.

(D) Exit access stairways and ramps shall be in accordance with Section 1103.4.8.

(E) Vertical openings that comply with the requirements of Section 803.2.1 of the IEBC®.

(3) Section 1104.1 General. This section has been modified to allow the means of egress in an existing building to be considered as complying if in the opinion of both the building code official and the fire code official they do not constitute a distinct hazard to life. This section has been modified to read: 1104.1 General. Means of egress in existing buildings shall comply with the minimum egress requirements when specified in Table 1103.1 as further enumerated in Section 1104.2 through 1104.25 or the building code that applied at the time of construction, if, in the opinions of the building official and the fire code official, they do not constitute a distinct hazard to life. Existing buildings that were not required to comply with a building code at the time of construction shall comply with the minimum egress requirements when specified in Table 1103.1 as further enumerated in Sections 1104.2 through 1104.25.

(4) Section 1104.18 Dead ends. This section has been modified to add another exception to the requirements of this section provided the dead ends comply with the requirements of Section 705.6 of the International Existing Building Code®. This section has been modified to read: 1104.18 Dead ends. Where more than one exit or exit access doorway is required, the exit access shall be arranged such that dead ends do not exceed the limits specified in Table 1104.18. In Group I-2, in smoke compartments containing patient sleeping rooms and treatment rooms, dead end corridors shall be in accordance with Section 1105.5.6. Exceptions:

(A) A dead-end passageway or corridor shall not be limited in length where the length of the dead-end passageway or corridor is less than 2.5 time the least width of the dead-end passageway or corridor.

(B) Dead ends that comply with the requirements of Section 805.6 of the IEBC®.

(5) Section 1104.25 Egress path markings. This section, including the exception, has been moved and renumbered into the newly created Appendix N, entitled "Egress Path Markings for Existing Buildings" and is not adopted as a minimum standard for residential or commercial fire prevention and fire protection systems within the State of Oklahoma. The section number 1104.25 itself, will stay as part of this code for numbering alignment but will not have any requirements attached to it.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15]

748:20-3-13.1. IFC® 2015 Chapter 57 Flammable and Combustible Liquids [RENUMBERED TO 748:20-3-13.4.]

[Source: Added at 32 Ok Reg 2270, eff 11-1-15, Amended at 34 OK Reg 2107, eff 9-15-17]

748:20-3-13.2. IFC® 2015 Chapter 23 Motor Fuel-Dispensing Facilities and Repair Garages Chapter 23 of the IFC® 2015 is adopted with the following modifications:

(1) Section 2301.7 Liquid natural gas (LNG) motor fuel-dispensing facilities. This section has been added to clarify that motor fuel-dispensing facilities for LNG shall comply with the requirements of Section 2303 and Chapter 55. This section has been added to read: 2301.7 Liquid natural gas motor fuel-dispensing facilities. Motor fuel-dispensing facilities utilizing liquid natural gas (LNG) fuel shall comply with the requirements of Section 2303 and Chapter 55.

(2) Section 2302 Definitions. This section has been modified to add to the terms "Main Railroad Track" and "Dispensing Area" to the list of terms defined in Chapter 2. This section has been modified to read: 2302.1 Definitions. The following terms are defined in Chapter 2:

(A) AIRCRAFT MOTOR-VEHICLE FUEL-DISPENSING FACILITY.

(B) ALCOHOL-BLENDED FUELS.

(C) AUTOMOTIVE MOTOR FUEL-DISPENSING FACILITY.

(D) DISPENSING AREA.

(E) DISPENSING DEVICE, OVERHEAD TYPE.

(F) FLEET VEHICLE MOTOR FUEL-DISPENSING FACILITY.

(G) LIQUEFIED NATURAL GAS (LNG).

(H) MAIN RAILROAD TRACK.

(I) MARINE MOTOR FUEL-DISPENSING FACILITY.

(J) REPAIR GARAGE.

(K) SELF-SERVICE MOTOR FUEL-DISPENSING FACILITY.

(3) Section 2303.1 Location of dispensing devices. This section has been modified to provide a sixth requirement when different types of fuel-dispensing devices for different fuels are located under the same canopy to prevent the accumulation or entrapment of ignitable vapors or all the electrical equipment located under the canopy must be suitable for Class I, Division 2 hazardous (classified) location. This section has been modified to read: 2303.1 Location of dispensing devices. Dispensing devices shall be located as follows:

(A) Ten feet (3048 mm) or more from lot lines.

(B) Ten feet (3048 mm) or more from buildings having combustible exterior wall surfaces or buildings having noncombustible exterior wall surfaces that are not part of a 1-hour-fire-resistance-rated assembly or buildings having combustible overhangs. Exception: Canopies constructed in accordance with the International Building Code® providing weather protection for the fuel islands.

(C) Such that all portions of the vehicle being fueled will be on the premises of the motor fuel-dispensing facility.

(D) Such that the nozzle, when the hose is fully extended, will not reach within 5 feet (1524 mm) of building openings.

(E) Twenty feet (6096 mm) or more from fixed sources of ignition.

(F) Where compressed natural gas (CNG), LNG, or Hydrogen motor fuel-dispensing devices are installed beneath a canopy or within an enclosure, either the canopy or enclosure shall be designed to prevent the accumulation or entrapment of ignitable vapors, including provisions for natural or mechanical ventilation means, or all electrical equipment installed beneath the canopy or within the enclosure shall be suitable for Class I, Division 2 hazardous (classified) locations. Tank vents that are installed within or attached to the canopy or enclosure shall extend a minimum of 5 feet (1524 mm) above the highest projection of the canopy. Compression and storage equipment located on top of the motor fuel-dispensing facility canopies shall be in accordance with current State of Oklahoma adopted International Fire Code®, Section 2309 and International Building Code®, Section 406.

(4) Section 2303.2.1 Local emergency disconnect switches. This section has been added to clarify when local emergency disconnect switches are required and when those switches are required to be interlocked with other local emergency disconnect switches. This section has been added to read: 2303.2.1 Local emergency disconnect switches. A local emergency disconnect switch, provided within 20 feet (6096 mm) of any dispensing unit shall be interlocked with all other dispensing units of the same fuel type and all other dispensing devices located within 20 feet (6096 mm) of the local emergency disconnect switch.

(5) Section 2303.2.2 Emergency disconnect switch lighting. This section has been added to clarify the requirements for providing illumination for emergency disconnect switch lighting. This section has been

added to read: 2303.2.2 Emergency disconnect switch lighting. Permanent lighting shall be provided during hours of operation in times of darkness at all dispensing devices, required signage, emergency disconnects and emergency shutdown controls. The lighting shall be designed to provide illumination such that all dispensing devices, required signage, emergency disconnect switches and emergency shutdown controls are visible to the operator.

(6) Section 2304.3.7 Quantity Limits. This section has been modified to include an exception to the requirement that dispensing devices at unsupervised locations be programmed or set to limit uninterrupted fuel delivery to 25 gallons and require manual action to resume delivery. This section has been modified to read: 2304.3.7 Quantity limits. Dispensing equipment used at unsupervised locations shall comply with one of the following:

(A) Dispensing devices shall be programmed or set to limit uninterrupted fuel delivery to 25 gallons (95 L) and require a manual action to resume delivery. Exception: Dispensing devices that are equipped with a listed breakaway device or equal approved by the Authority Having Jurisdiction. Such emergency breakaway device shall be installed, maintained and replaced in accordance with the manufacturer's instructions.

(B) The amount of fuel being dispensed shall be limited in quantity by a preprogrammed card as approved.

(7) Section 2307.3 Attendants. This section has been modified to add an exception to the requirement for an attendant when the dispensing equipment meets the guidelines of NFPA® 58 for a "Low emission transfer." This section has been modified to read: 2307.3 Attendants. Motor fuel-dispensing operations for LP-gas shall be conducted by qualified attendants or in accordance with Section 2307.7 by persons trained in the proper handling of LP-gas. Exception: When the dispensing equipment meets the guidelines of NFPA® 58 for "Low emission transfer" an attendant is not required.

(8) Section 2307.4.1 Low emission transfer. This section has been added to clarify when the dispensing equipment meets the guidelines of NFPA® 58, Section 6.28.5 for "Low emission transfer" then the transfer distance shall be reduced by one-half. This section has been modified to read: 2307.4.1 Low emission transfer. When the dispensing equipment is installed in accordance with Section 6.28.5 of NFPA® 58 for "Low emission transfer," the transfer distance requirements in Table 6.5.2.1 and Section 6.25.4.3(1) of NFPA® 58 shall be reduced by one-half.

(9) Section 2307.7 Public fueling of motor vehicles. This section has been modified to provide an exception to the owner's requirement to train users when the dispensing equipment meets the guidelines of NFPA® 58 for a "Low emission transfer." This section has been added to read: 2307.7 Public fueling of motor vehicles.

(A) Self-service LP-gas dispensing systems, including key, code and card lock dispensing systems, shall be limited to the filling of permanently mounted containers providing fuel to the LP-gas powered vehicle.

(B) The requirements for self-service LP-gas dispensing systems shall be in accordance with the following:

(i) The arrangement and operation of the transfer of product into a vehicle shall be in accordance with this section and Chapter 61.

(ii) The system shall be provided with an emergency shut-off switch located within 100 feet (30 480 mm) of, but not less than 20 feet (6096 mm) from dispensers.

(iii) The owner of the LP-gas motor fuel-dispensing facility or the owner's designee shall provide for the safe operation of the system and the training of users. Exception: If the LP-gas motor fuel-dispensing facility meets the requirements of a low emission transfer station per NFPA® 58, then training of the users is not the responsibility of the facility.

(iv) The dispenser and hose-end valve shall release not more than 1/8 fluid ounce (4 cc) of liquid to the atmosphere upon breaking the connection with the fill valve on the vehicle.

(v) Portable fire extinguishers shall be provided in accordance with Section 2305.5.

(vi) Warning signs shall be provided in accordance with Section 2305.6.

(vii) The area around the dispenser shall be maintained in accordance with Section 2305.7.

(10) Section 2308.3.2 Warning signs. This section has been added to include warning signs to be posted on Compressed Natural Gas (CNG) dispensing devices. This section has been added to read: 2308.3.2

Warning signs. Warning signs complying with Section 310 shall be posted as follows:

(A) Warning sign(s) shall be conspicuously posted within sight of each dispenser in the fuel dispensing area and shall state the following:

(i) No smoking

(ii) Shut off motor

(iii) Flammable Gas

(iv) Natural gas vehicle fuel cylinders shall be inspected at intervals not exceeding 3 years or 36,000 miles to ensure safe operation of the vehicle

(v) Natural gas fuel cylinders past their end-of-life date shall not be refueled and shall be removed from service.

(B) A warning sign with the words "No smoking, flammable gas" shall be posted in all compressor and storage areas.

(C) The lettering on the sign shall be legible and large enough to be visible from each point of transfer.

(D) The service pressure of each dispenser shall be posted in view of the operator.

(11) Section 2308.4 Private fueling of motor vehicles. This section has been modified to allow for the industry practice of utilizing CNG trailers that are not permanently attached to CNG powered vehicles and delete the requirement for the owner to ensure the user of a CNG powered vehicle to be properly trained on the vehicle's filling procedures. This section has been modified to read: 2308.4 Private fueling of motor vehicles.

(A) Self-service CNG dispensing systems, including key, code and card lock dispensing systems, shall be limited to the filling of approved, permanently mounted fuel containers.

(B) In addition to the requirements in Section 2305, the owner of a self-service CNG motor fuel-dispensing facility shall ensure the safe operation of the system.

(12) Section 2308.7 Emergency shutdown control. This section has been modified to change the word "control" to "devices" in the section heading, clarify the requirements of the emergency manual shutdown device and provide an exception to those requirements for time-fill applications. This section has been modified to read: 2308.7 Emergency shutdown devices. A remote and local emergency manual shutdown device shall be provided. Upon activation, the emergency shutdown system shall automatically close valves between the main gas supply and the compressor and between the storage containers and dispensers, and automatically shut off the power supply to the compressor and the following associated devices: dispensing enclosures; remote pumps; power, control, and signal circuits; and electrical equipment in the hazardous (classified) locations surrounding the fuel dispensing enclosures. All labeled emergency shutdown devices shall be interconnected, whether required or not. Resetting from an emergency shutoff condition shall require manual intervention and the manner of resetting shall be approved by the Authority Having Jurisdiction. Exception: In time-fill applications, in lieu of a defined remote and local emergency manual shutdown device, an emergency manual shutdown device shall be provided within 50 feet (15 240 mm) of each fixed point of dispensing hose attachment and located inside and outside the compressor area within 10 feet (3048 mm) of the main access to the compressor area.

(13) Section 2308.7.1 Remote emergency shutdown device. This section has been added to clarify the distance requirements remote emergency manual shutdown device placement and provide for an exception to the maximum distance required when located within line of sight of the dispensing enclosures and approved by the Authority Having Jurisdiction. This section has been added to read: 2308.7.1 Remote emergency shutdown device. A remote emergency manual shutdown device shall be located within 100 feet (30 480 mm) of, but not less than 20 feet (6096 mm) from all dispensing enclosures and shall be provided inside and outside the compressor area within 10 feet (3048 mm) of the main access to the compressor area. Exception: A remote emergency shutdown device may be located greater than 100 feet (30 480 mm) from one or more dispensing enclosures when within line of sight of the dispensing enclosures and approved by the Authority Having Jurisdiction.

(14) Section 2308.7.2 Local emergency shutdown device. This section has been added to require a local emergency manual shutdown device be provided within 15 feet (4572 mm) of each dispensing enclosure.

This section has been added to read: 2308.7.2 Local emergency shutdown device. A local emergency manual shutdown device shall be located within 15 feet (4572 mm) of each dispensing enclosure.

(15) Section 2311.4.3 Ventilation. This section has been modified to clarify the point at which the mechanical ventilation should be exhausted in a basement or pit. This section has been modified to read: 2311.4.3. Ventilation. Where class I liquids or LP-gas are stored or used within a building having a basement or pit wherein flammable vapors could accumulate, the basement or pit shall be provided with mechanical ventilation in accordance with the International Mechanical Code®, at a minimum rate of 1 1/2 cubic feet per minute per square foot (cfm/square foot) [0.0008 cubic meters per (second meter squared)] taken from a point within 12 inches (305 mm) of the floor to prevent the accumulation of flammable vapors.

(16) Section 2311.5 Preparation of vehicles for repair. This section has been modified to clarify Liquefied Natural Gas vehicles comply with Section 2311.5.1 as applicable. This section has been modified to read: 2311.5 Preparation of vehicles for repair.

(A) For vehicles powered by gaseous fuels, the fuel shutoff valves shall be closed prior to repairing any portion of the vehicle fuel system.

(B) Vehicles powered by gaseous fuels in which the fuel system has been damaged shall be inspected and evaluated for fuel system integrity prior to being brought into the repair garage. The inspection shall include testing of the entire fuel delivery system for leakage. Liquefied Natural Gas (LNG) vehicles shall comply with Section 2311.5.1 as applicable.

(17) Section 2311.5.1 Liquefied Natural Gas (LNG) This section has been added to clarify the process needed to measure and record the pressure of the LNG vehicle fuel system prior to and on every third day while in the repair facility to ensure the fuel pressure does not exceed the maximum allowable fuel pressure. This section has been added to read: 2311.5.1 Liquefied Natural Gas. Liquefied Natural Gas (LNG) vehicle fuel system pressure shall be measured and recorded prior to entering the repair facility and at least every third day the vehicle remains in the building. Records shall be posted on the windshield of the vehicle. The maximum allowable system pressure shall be no more than 170 psig. Pressure above 170 psig shall be reduced by operating the vehicle, or limited venting outdoors as required.

(18) Section 2311.7 Repair garages for vehicles fueled by lighter-than-air fuels. This section has been modified to include a third exception for repair garages where work is conducted only on vehicles that have been defueled and their systems purged with nitrogen gas and where there are standard operating procedures to document and maintain the fueling status throughout the repair operations are approved. This section has been modified to read: 2311.7 Repair garages for vehicles fueled by lighter-than-air fuels. Repair garages for the conversion and repair of vehicles that use CNG, liquefied natural gas (LNG), hydrogen or other lighter-than-air motor fuels shall be in accordance with Sections 2311.7 through 2311.7.2.3 in addition to the other requirements of Section 2311. Exceptions:

(A) Repair garages where work is conducted only on vehicles that have been defueled and their systems purged with nitrogen gas, and where standard operating procedures to document and maintain the fueling status throughout the repair operations has been approved.

(B) Repair garages where work is not performed on the fuel system and is limited to exchange of parts and maintenance not requiring open flame or welding on the CNG-, LNG-, hydrogen- or other lighter-than-air-fueled motor vehicle.

(C) Repair garages for hydrogen-fueled vehicles where work is not performed on the hydrogen storage tank and is limited to the exchange of parts and maintenance not requiring open flame or welding on the hydrogen-fueled vehicle. During the work, the entire hydrogen fuel system shall contain a quantity that is less than 200 cubic feet (5.6 cubic meters) of hydrogen.

(19) Section 2311.7.1.1 Design. This section has been modified to clarify exhaust outlets should be located within 18 inches (475 mm) of the high point of the room on exterior walls or the roof and to change the ventilation rate from not less than 1 cubic foot per minute per 12 cubic feet of room volume to 1 cubic foot per square foot of room area. This section has been modified to read: 2311.7. 1.1 Design.

(A) Indoor locations shall be ventilated utilizing air supply inlets and exhaust outlets arranged to provide uniform air movement to the extent practical. Inlets shall be uniformly arranged on exterior

walls near floor level. Outlets shall be located within 18 inches (457 mm) of the high point of the room in exterior walls or the roof.

(B) Ventilation shall be by a continuous mechanical ventilation system or by a mechanical ventilation system activated by a continuously monitoring natural gas detection system or, for hydrogen, a continuously monitoring flammable gas detection system, each activating at a gas concentration of not more than 25 percent of the lower flammable limit (LFL). In all cases, the system shall shut down the fueling system in the event of failure of the ventilation system.

(C) The ventilation rate shall be not less than 1 cubic foot per minute per square foot [0.0051 cubic meters per (second square meter)] of room area.

[Source: Added at 34 Ok Reg 2107, eff 9-15-17]

748:20-3-13.3. IFC® 2015 Chapter 55 Cryogenic Fluids

Chapter 55 of the IFC® is adopted with the following modification: Section 5501.1 Scope. This section has been modified to add a third exception for liquefied natural gas (LNG) facilities for LNG vehicular applications to comply with Chapter 23 and NFPA® 52. This section has been modified to read: 5501.1 Scope.

(1) Storage, use and handling of cryogenic fluids shall comply with this chapter and NFPA® 55.

Cryogenic fluids classified as hazardous materials shall also comply with the general requirements of Chapter 50. Partially full containers containing residual cryogenic fluids shall be considered as full for the purposes of the controls required. Exceptions:

(A) Fluids used as refrigerants in refrigeration systems (see Section 606).

(B) Liquefied natural gas (LNG), which shall comply with NFPA® 59 A.

(C) LNG facilities for LNG vehicular applications, which shall comply with Chapter 23 and NFPA® 52.

(2) Oxidizing cryogenic fluids, including oxygen, shall comply with Chapter 63, as applicable.

(3) Flammable cryogenic fluids, including hydrogen, methane, and carbon monoxide, shall comply with Chapters 23 and 58, as applicable.

(4) Inert cryogenic fluids, including argon, helium and nitrogen, shall comply with ANSI/CGA P-18.

[Source: Added at 34 Ok Reg 2107, eff 9-15-17]

748:20-3-13.4. IFC® 2015 Chapter 57 Flammable and Combustible Liquids

Chapter 57 of the IFC® 2015 is adopted with the following modification: Section 5705.5 Alcohol-based hand rubs classified as Class I or II. This section has been modified to require guards or shields on alcohol-based hand rub dispensers when installed over a carpeted area. This section has been modified to read: 5705.5 Alcohol-based hand rubs classified as Class I or II liquids. The use of wall-mounted dispensers containing alcohol-based hand rubs classified as Class I or II liquids shall be in accordance with all of the following:

(1) The maximum capacity of each dispenser shall be 68 ounces (2 L).

(2) The minimum separation between dispensers shall be 48 inches (1219 mm)

(3) The dispensers shall not be installed above, below, or closer than 1 inch (25 mm) to an electrical receptacle, switch, appliance, device or other ignition source. The wall space between the dispenser and the floor or intervening counter top shall be free of electrical receptacles, switches, appliances, devices or other ignition sources.

(4) Dispensers shall be mounted so that the bottom of the dispenser is not less than 42 inches (1067 mm) and not more than 48 inches (1219 mm) above the finished floor.

(5) Dispensers shall not release their contents except when the dispenser is manually activated. Facilities shall be permitted to install and use automatically activated "touch free" alcohol-based hand-rub dispensing devices with the following requirements:

(A) The facility or persons responsible for the dispensers shall test the dispensers each time a new refill is installed in accordance with the manufacturer's care and use instructions.

(B) Dispensers shall be designed and must operate in a manner that ensures accidental or malicious activations of the dispensing devices are minimized. At a minimum, all devices subject to or used in accordance with this section shall have the following safety features:

(i) Any activations of the dispenser shall only occur when an object is placed within 4 inches (98 mm) of the sensing device.

- (ii) The dispenser shall not dispense more than the amount required for hand hygiene consistent with label instructions as regulated by the United States Food and Drug Administration (USFDA).
 - (iii) An object placed within the activation zone and left in place will cause only one activation.
- (6) Storage and use of alcohol-based hand rubs shall be in accordance with the applicable provisions of Sections 5704 and 5705.
- (7) Dispensers when installed over a carpeted area shall have a guard or shield to prevent alcohol-based hand rub product from dispensing onto the floor.
- [Source: Added at 34 Ok Reg 2107, eff 9-15-17]

748:20-3-13.5. IFC® 2015 Chapter 61 Liquefied Petroleum Gases

Chapter 61 of the IFC® 2015 is adopted with the following modifications:

- (1) Section 6106.1 Attendants. This section has been modified to provide an exception to the requirement for a qualified attendant if the motor fuel-dispensing equipment meets the guidelines of NFPA® 58 for a "Low emission transfer." This section has been modified to read: 6106.1 Attendants. Dispensing of LP-gas shall be performed by a qualified attendant. Exception: When the dispensing equipment meets the guidelines of NFPA® 58 for "Low emission transfer" an attendant is not required.
- (2) Section 6106.2 Overfilling. This section has been modified to include an overfilling prevention device on the container as one of the ways to measure the volume in the container. This section has been modified to read: 6106.2 Overfilling. LP-gas containers shall not be filled or maintained with LP-gas in excess of either the volume determined using the fixed liquid-level gauge installed in accordance with the manufacturer's specifications and in accordance with Section 5.7.5 of NFPA® 58, the volume determined by the overfilling prevention device installed on the container, or the weight determined by the required percentage of water capacity marked on the container. Portable LP-gas containers shall not be refilled unless equipped with an overfilling prevention device (OPD) where required by Section 5.7.3 of NFPA® 58.

[Source: Added at 34 Ok Reg 2107, eff 9-15-17]

748:20-3-14. IFC® 2015 Chapter 80 Referenced Standards

Chapter 80 of the IFC® 2015 is adopted with the following modifications:

- (1) The reference to the International Building Code® has been modified to include after the title the words "as adopted and modified by the State of Oklahoma through the OUBCC." This section has been modified to read: IBC®-15 International Building Code® as adopted and modified by the State of Oklahoma through the OUBCC.
- (2) The reference to the International Existing Building Code® has been modified to include after the title the words "as adopted and modified by the State of Oklahoma through the OUBCC." This section has been modified to read: IEBC®-15 International Existing Building Code® as adopted and modified by the State of Oklahoma through the OUBCC.
- (3) The reference to the International Fuel Gas Code® has been modified to include after the title the words "as adopted and modified by the State of Oklahoma through the OUBCC." This section has been modified to read: IFGC®-15 International Fuel Gas Code® as adopted and modified by the State of Oklahoma through the OUBCC.
- (4) The reference to the International Mechanical Code® has been modified to include after the title the words "as adopted and modified by the State of Oklahoma through the OUBCC." This section has been modified to read: IMC®-15 International Mechanical Code® as adopted and modified by the State of Oklahoma through the OUBCC.
- (5) The reference to the International Plumbing Code® has been modified to include after the title the words "as adopted and modified by the State of Oklahoma through OUBCC." This section has been modified to read: IPC®-15 International Plumbing Code® as adopted and modified by the State of Oklahoma through the OUBCC.
- (6) The reference to the International Residential Code® has been modified to include after the title the words "as adopted and modified by the State of Oklahoma through the OUBCC." This section has been modified to read: IRC®-15 International Residential Code® as adopted and modified by the State of Oklahoma through the OUBCC.

(7) The referenced standard for NFPA® 2 Hydrogen Technologies Code has been modified to change the edition year from 2011 to 2016. This Section has been modified to read: 02-16 Hydrogen Technologies Code.

(8) The referenced standard for NFPA® 70® National Electrical Code® has been modified to include after the title the words "as adopted and modified by the State of Oklahoma through the OUBCC." This section has been modified to read: 70-14 National Electrical Code® as adopted and modified by the State of Oklahoma through the OUBCC.

[Source: Added at 29 Ok Reg 1646, eff 11-1-12, Amended at 32 Ok Reg 2270, eff 11-1-15, Amended at 34 OK Reg 2107, eff 9-15-17]

748:20-3-15. Appendix N, Egress Path Markings for Existing Buildings

This appendix has been newly created and entitled "Appendix N, Egress Path Markings for Existing Buildings." The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.

(1) Section N101 General. This section has been added to clarify scope and intent for this appendix. This section has been added to read: N101 General.

(A) Section N101.1 Scope. This section has been added to specify the provisions of the appendix and shall apply to existing high-rise buildings of Group A, B, E, I, M and R-1 occupancies. This section has been added to read: N101.1 Scope. The provisions of this appendix shall apply to existing high-rise buildings of Group A, B, E, I, M, and R-1 occupancies in addition to the requirements of Chapter 11.

(B) Section N101.2 Intent. This section has been added to specify the intent of this appendix is to provide an additional degree of life-safety to persons occupying existing high-rise buildings of Group A, B, E, I, M and R-1 occupancies. This section has been added to read: N101.2 Intent. The intent of this appendix is to provide an additional degree of life-safety to persons occupying existing high-rise buildings of Group A, B, E, I, M and R-1 occupancies where such buildings do not contain luminous egress path markings.

(2) Section N102. Egress path markings. This section, formerly numbered Section 1104.25 has been moved into Appendix N entitled "Egress Path Markings for Existing Buildings." The section has been added to read: N102. Egress path markings. Existing high-rise buildings of Group A, B, E, I, M and R-1 occupancies shall be provided with luminous egress path markings in accordance with Section 1025. Exception: Open, unenclosed stairwells in historic buildings designated as historic under a state or local historic preservation program.

[Source: Added at 32 Ok Reg 2270, eff 11-1-15]