

Kathy Hehnly

Public Comment #1

From: Scott Boyle <Scott.Boyle@edmondok.com>
Sent: Friday, September 04, 2020 3:56 PM
To: Kathy Hehnly
Cc: Bryant Van Fossen
Subject: [EXTERNAL] FW: Public Comment
Attachments: Revisions.pdf; Supporting Information.pdf; PCF for Proposed Rules Signed.pdf

Follow Up Flag: Follow up
Flag Status: Flagged

Kathy,

We would like to resubmit our previous public comments for further consideration.

Thanks,

Scott Boyle

*Department Manager
Building & Fire Code Services
City of Edmond
Office: 405-359-4788
scott.boyle@edmondok.com*

From: Bryant Van Fossen <Bryant.Vanfossen@edmondok.com>
Sent: Friday, March 6, 2020 11:42 AM
To: kathy.hehnly@oubcc.ok.gov
Cc: Scott Boyle <Scott.Boyle@edmondok.com>
Subject: Public Comment

Kathy,

Please see the attached documents for our comment on the proposed OUBCC Amendment to the IFC.

Please feel free to give me a call with any questions.

Have a great weekend,

Bryant VanFossen, EI, GSP
Fire Protection Specialist
Building & Fire Code Services
City of Edmond
(405)359-4664

Oklahoma Uniform Building Code Commission

Public Comment Form for Proposed Rules

Title 748 O.A.C. Chapter 20 - Adopted Codes

INSTRUCTIONS: Please type or print clearly. Form must be signed. Any form not signed or filled out completely, may not be considered. Each requested change must be on a separate form.

Submitter's Contact Information:

Name: Scott Boyle Date: 5 MAR 2020
Company: City of Edmond Building Department
Address: 10 S. Littler
City: Edmond State: OK Zip: 73034
Phone: 405-359-4788 Ext: _____ Fax: _____
Email: scott.boyle@edmondok.com

Will this proposed change increase the cost of construction? Yes No

Which area of the rules should be modified?

Rule Section 748: 20- 4 - 11 Section Title: IFC 2018 Chapter 6 Building Services and Systems
Letter/Item Number: (1) Section [M] 607.2 Exception (E) Page in proposed rules: 28

Please check the action to be taken for this proposed change:

Revise as follows Delete as follows Add new text as follows Delete with substitute

Show the proposed **NEW, REVISED, OR DELETED TEXT** in legislative format. Line through text to be deleted and underline text to be added or revised.


See Attached.

* If your text does not fit in the space provided, type "See Attached" and submit text as a separate file

Supporting information: State purpose and reason for the change and provide substantiation to support proposed change.

See Attached.

* If your text does not fit in the space provided, type "See Attached" and submit text as a separate file

Signature: 

Send completed "Public Comment Form" to:
Oklahoma Uniform Building Code Commission, PO Box 12540, Oklahoma City, OK 73157
Email to: Kathy.Hehnly@oubcc.ok.gov or Fax to: 405-521-6504

Revise as follows: (E) Where required, a Type I hood equipped with a suppression system listed in accordance with UL 300A, or meeting the requirements of ICC-ES 1031, shall be permitted in new construction and renovation of adult day care facilities or child day care facilities having an occupant load of 16 or less, with a single domestic medium duty cooking appliance, utilized for warming food only.

Or,

Revise as follows: (E) Where ~~required~~ approved, a Type II hood equipped with a suppression system listed in accordance with UL 300A, or meeting the requirements of ICC-ES 1031, shall be permitted in new construction and renovation of adult day care facilities or child day care facilities having an occupant load of 16 or less, with a single domestic medium duty cooking appliance, utilized for warming food only.

Or,

~~Delete as follows: (E) Where required, a Type II hood equipped with a suppression system listed in accordance with UL 300A, or meeting the requirements of ICC-ES 1031, shall be permitted in new construction and renovation of adult day care facilities or child day care facilities having an occupant load of 16 or less, with a single domestic medium duty cooking appliance, utilized for warming food only.~~

Or,

Add new text as follows: (E) Where required, a Type II hood equipped with a suppression system listed in accordance with UL 300A, or meeting the requirements of ICC-ES 1031, shall be permitted in new construction and renovation of adult day care facilities or child day care facilities having an occupant load of 16 or less, with a single domestic medium duty cooking appliance, utilized for warming food only.

- (1) A permanent and fixed label that will communicate that no cooking or frying is allowed at this cooking appliance and that it is a Type II hood with a hood suppression system, not to be confused with a Type I hood.

“Revise as follows: (E) Where required, a Type I hood equipped with a suppression system listed in accordance with UL 300A, or meeting the requirements of ICC-ES 1031, shall be permitted in new construction and renovation of adult day care facilities or child day care facilities having an occupant load of 16 or less, with a single domestic medium duty cooking appliance, utilized for warming food only.”

Reason for this change: If the concern is that these occupancies are already producing grease laden vapors then a Type I hood is required by this Section (607.2) and Section 507.2 of the IMC.

Or,

“Revise as follows: (E) Where ~~required~~ approved, a Type II hood equipped with a suppression system listed in accordance with UL 300A, or meeting the requirements of ICC-ES 1031, shall be permitted in new construction and renovation of adult day care facilities or child day care facilities having an occupant load of 16 or less, with a single domestic medium duty cooking appliance, utilized for warming food only.”

Reason for this change: To allow each municipality to decide for themselves whether decreasing the level of safety is acceptable. If the concern is that these occupancies are already producing grease laden vapors then a Type I hood is required by this section and Section 507.2 of the IMC and thus, this requirement is decreasing the level of safety already required. Also, allowing this Type II hood with a suppression system will lead to much confusion in the future as tenants move in and out as to what type of hood is installed. If these occupancies are not producing grease with a single domestic medium duty cooking appliance that is strictly utilized for warming purposes only, then a suppression system is not warranted.

Or,

~~“Delete as follows: (E) Where required, a Type II hood equipped with a suppression system listed in accordance with UL 300A, or meeting the requirements of ICC-ES 1031, shall be permitted in new construction and renovation of adult day care facilities or child day care facilities having an occupant load of 16 or less, with a single domestic medium duty cooking appliance, utilized for warming food only.”~~

Reason for this change: If the concern is that these occupancies are already producing grease laden vapors then a Type I hood is required by this section and Section 507.2 of the IMC and thus, this requirement is decreasing the level of safety already required. Also, allowing this Type II hood with a suppression system will lead to much confusion in the future as tenants move in and out as to what type of hood is installed.

Or,

“Add new text as follows: (E) Where required, a Type II hood equipped with a suppression system listed in accordance with UL 300A, or meeting the requirements of ICC-ES 1031, shall be permitted in new construction and renovation of adult day care facilities or child day care

facilities having an occupant load of 16 or less, with a single domestic medium duty cooking appliance, utilized for warming food only.

- (1) A permanent and fixed label that will communicate that no cooking or frying is allowed at this cooking appliance and that it is a Type II hood with a hood suppression system, not to be confused with a Type I hood."

Reason for this change: Allowing this Type II hood with a suppression system will lead to much confusion in the future as tenants move in and out as to what type of hood is installed.