

Oklahoma Uniform Building Code Commission SEP 17 2020

Public Comment Form for Proposed Rules

OUBCC

Title 748 O.A.C. Chapter 20 - Adopted Codes

INSTRUCTIONS: Please type or print clearly. Form must be signed. Any form not signed or filled out completely, may not be considered. Each requested change must be on a separate form.

Submitter's Contact Information:

Name: Jonathan Sargeant Date: September 16, 2020

Company: OmegaFlex

Address: 1801 Crystal Drive, Apartment 711

City: Arlington State: VA Zip: 22202

Phone: (703) 946-5848 Ext: Fax:

Email: jonathan.sargeant@omegaflex.com

Will this proposed change increase the cost of construction? Yes [] No [x]

Which area of the rules should be modified?

Rule Section 748: 20- 12 - 13 Section Title: IFGC® 2018 Chapter 8 Referenced Standards

Letter/Item Number: New Item (8) Page in proposed rules: 16

Please check the action to be taken for this proposed change:

Revise as follows [x] Delete as follows [] Add new text as follows [] Delete with substitute []

Show the proposed NEW, REVISED, OR DELETED TEXT in legislative format. Line through text to be deleted and underline text to be added or revised.

LC 1/CSA 6.26—~~2013~~18: Fuel Gas Piping Systems Using Corrugated Stainless Steel Tubing (CSST)
403.5.5

* If your text does not fit in the space provided, type "See Attached" and submit text as a separate file

Supporting information: State purpose and reason for the change and provide substantiation to support proposed change.

CSST manufacturers use a conductive jacket material and/or multi-layered design to arrive at a more robust, arc-resistant product. Four of the five CSST suppliers now produce an arc-resistant product. Two of these manufacturers produce only arc-resistant CSST for sale in the United States. Along with this newer and safer product comes revised installation/bonding practices as reflected in the 2018 IFGC but not in the 2013 LC-1 standard. Updating the IFGC with the new LC-1 will permit the use of a new and safer product in Oklahoma.

* If your text does not fit in the space provided, type "See Attached" and submit text as a separate file

Signature: Jonathan S. Sargeant

Send completed "Public Comment Form" to:
Oklahoma Uniform Building Code Commission, PO Box 12540, Oklahoma City, OK 73157
Email to: Kathy.Hehnl@oubcc.ok.gov or Fax to: 405-521-6504