

Residential Building Technical Committee

Meeting Minutes: 11.4.2010

Voting Members Present

Chris Ramseyer, Chair
Curtis McCarty
Todd Booze
Howard Kelsey
Bob Pratt
Ed Steiner
Roger Gose
Sam Gresham
Jimmy Ray

- Adopt minutes from previous meeting.
 - o Voted unanimously to accept the minutes.

- Reviewed Section R802.3.
- Motion to add "Definition of a brace – 1) A triangular configuration with a horizontal tie or rafter. 2) King post or similar"
 - o Voted unanimously.

- Reviewed Section R801.3.
- Motion to remove from the code.
 - o Voted unanimously.

- Reviewed Section R802.5.1.
- Motion to add "2x6 braces on 6 ft centers may be accepted in place of the 2x4 braces on 4 ft centers."
 - o Voted unanimously to accept this motion

- Reviewed Section R1103.2.2.
- Motion to add "visual inspection may be used instead of the roughin test and the post construction test"
 - o Voted unanimously to accept this motion

- Reviewed Section R1103.1.1.
- Motion to remove from the code
 - o Voted unanimously to accept this motion

- Reviewed Section R1103.6.

- Motion to remove from the code
 - o Voted unanimously to accept this motion

- Reviewed Section R1103.8.3.
- Motion to remove the first sentence from the code
 - o Voted unanimously to accept this motion

- Reviewed Section R1104.1.
- Motion to exempt can/recessed lights from this section of the code
 - o Voted unanimously to accept this motion

- Reviewed Section R1102.4.3.
- Motion to remove "gasketed doors" from this section of the code
 - o Voted unanimously to accept this motion

- Reviewed Section R302.1.
- Motion to revise table R302.1 for minimum fire separation distance from 5 ft to 3 ft
 - o Voted unanimously to accept this motion

- Reviewed Section R310.1.1.
- Motion to revise minimum clear opening from 5.7 sq ft to 5 sq ft
 - o Voted unanimously to accept this motion

- Reviewed Section R323.1.
- Motion to remove "In addition to other applicable requirements in this code, storm shelters shall be constructed in accordance with ICC/NSSA 500." from the code.
 - o Voted unanimously to accept this motion

- Committee plan for November 16th meeting: 1) finish all issues in front of the committee 2) review work completed 3) open floor for discussion if time permits.
- Meeting was adjourned.