

Change of Scope

This addendum is to address a change to the scope of work for project proposed in the bid documents entitled “Specifications and Contract Documents, Okay 2016 Waterline Replacement Project – Phase 1”.

DIRECTIONS:

Strike item D under Article 5 of Bid Proposal and replace with the following language:

The project will begin on the west side of SH 16 at STA 57+68 and extend to STA 40+41. This will negate the need for highway crossing and related appurtenances. Scope of work shall include connection of existing service lines to the newly installed main line following successful sanitation of the line, shown by negative bacterial analyses, conducted for 2 consecutive days.

Modify item 1 of General Construction Notes (sheet 2 of project drawings) as follows:

“...pipe and fittings installed will be ~~HDPE pipe, DR 9, 200 psi.~~ PVC pipe, class 200. References to pipe size or diameter shall be IPS (iron pipe size).”